

CERTIFICATE

Of Conformity
ASTM F 1387-99(2005)
Piping and Tubing Mechanically Attached Fittings
For Tubefit Engineers.

Order No:

1403009019

Report No:

1403009019 (T) -12-001

Holder:

Tubefit Engineers

Unit No 2&3, Swamini Industrial Estate

Village Waliv, Vasai Dist. Thane- 401208

Product:

Tubefit Instrument Tubing & Pipe Connector

Identification:

TUBEFIT

This Certificate of Conformity is based on an evaluation of a sample of the above mentioned product. This is to certify that the tested sample is in conformity with relevant provisions of ASTM F 1387-99(2005); Piping and Tubing Mechanically Attached Fittings. This Certificate does not imply assessment of the production of the product and does not permit the use of a TUV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the report of the conformity according to the above standard.

Mumbai, 31st January, 2012.

Malcolm Dadina

Test Report for Type Examination of Pressure Equipment



Test: Type Examination					Test report/Test plan No: 1403009019 (T) -11-001					
Manufacturer/Person responsible for putting the equipment on the market: Tubefit Engineers. Unit No 2&3, Swamini Industrial Estate Village Waliv, Vasai, Dist. Thane- 401208				Factory: Tubefit Engineers. Unit No 2&3, Swamini Industrial Estate Village Waliv, Vasai, Dist. Thane- 401208						
Te	chnical data of type/type	family	: Tubefit Ins	trume	nt T	ubing & Pipe Co	onne	ector		
Drawing number – Generally as per Tubefit Engineers catalogue and associated data				Connectors (1/4"-1" OD Tube Sizes)				Connectors (6mm – 25mm OD Tube Sizes)		
Test Pressure PH [Bar]				times pressure rating of appropriate thickness tube on sampling bases				1.5 times pressure rating of appropriate thickness tube or sampling bases		
Category:							 			
Intended use:				Instrument tubing applications within Oil, Gas, Petrochem, Power and Marine industries						
Type identification:					Tu	befit Instrumen	t Tul	bing & Pipe Connector		
Ma	nufacturer logo:									
Service temperature (max) TS [°C]								Dependent upon material -75 to + 538 Deg C (316SS)		
dev	sting based on : Tubefit Er relopment test and validation ective: N/A			d	1	andards: eviations:	NON	ΓΜ F1387-99(2005) NE		
Tests and examinations: NO.OF SPICMEN				SIZE		TUBE WALL THICKNESS	DOCUMENT REFERANCE NO.			
1.	Examination of Specimen:		112 NOS.	1) ¼" 2) ½" 3) ¾" 4) 1"		0.035" 0.065" 0.083" 0.083"	TFE/ESP/4T TFE/ESP/8T TFE/ESP/12T TFE/ESP/16T			
2.	Pneumatic Proof Test:		112 NOS.	1) ½" 2) ½" 3) ¾" 4) 1"		0.035" 0.065" 0.083" 0.083"	TFE/PNU/4T TFE/PNU/8T TFE/PNU/12T TFE/PNU/16T			
3.	Hydrostatic Proof Test:		112 NOS.	1) ¼" 2) ½" 3) ¾" 4) 1"		0.035" 0.065" 0.083" 0.083"	TFE/HYD/4T TFE/HYD/8T TFE/HYD/12T TFE/HYD/16T			
4.	Impulse Test:		24 NOS.	1) ½" 2) ½" 3) ¾" 4) 1"		0.035" 0.065" 0.083"	TFE/IMP/4T TFE/IMP/8T TFE/IMP/12T TFE/IMP/16T			



5.	Flexure Fatigue Test:		24 NOS.	1) 1/4"	0.035"	TFE/FFT/4T	
				2) ½"	0.065"	TFE/FFT/8T	
		1		3) 3/4"	0.083"	TFE/FFT/12T	
				4) 1"	0.083"	TFE/FFT/16T	
6.	Tensile Test:		24 NOS.	1) 1/4"	0.035"	TFE/PLT/4T	
				2) 1/2"	0.065"	TFE/PLT/8T	
				3) 3/4"	0.083"	TFE/PLT/12T	
				4) 1"	0.083"	TFE/PLT/16T	
7.	Hydrostatic Burst Test:		16 NOS.	1) 1/4"	0.035"	TFE/HBT/4T	
				2) ½"	0.065"	TFE/HBT/8T	
				3) 3/4"	0.083"	TFE/HBT/12T	
				4) 1"	0.083"	TFE/HBT/16T	
8.	Repeated Assembly Test:		24 NOS.	1) 1/4"	0.035"	TFE/RIA/4T	
				2) ½"	0.065"	TFE/RIA/8T	
				3) 3/4"	0.083"	TFE/RIA/12T	
		The second second		4) 1"	0.083"	TFE/RIA/16T	
9.	Rotary Flexure Test:		24 NOS.	1) 1/4"	0.035"	TFE/RFT/4T	
	15			2) ½"	0.065"	TFE/RFT/8T	
				3) 3/4"	0.083"	TFE/RFT/12T	
				4) 1"	0.083"	TFE/RFT/16T	

Previously performed tests:

The Phastite joints in all sizes, shapes and listed tube thicknesses have been tested for hydro test, vacuum test, cycle test, and burst test.

Selection of test sample(s):

Quantity:

Total 112 NOS.SPECIMEN

Type:

Phastite type

Comments:

The samples are representatives for the type. The tests listed above were performed in compliance with the test requirements of the standards/regulations quoted in this test plan. The test results of item 1 ~ 9 have been examined for compliance with the test requirements of ASTM F1387-99(2005) and found satisfactory.

Location: Vasai, Mumbai

Date: 05/08/2008

Test Laboratory for Transportable Pressure Equipment

NR Jadine



Malcolm Dadina

Attachments: TFE/ESP/4T TO 16T, TFE/PNU/4T TO 16T, TFE/HYD/4T TO 16T, TFE/IMP/4T TO 16T,

TFE/FFT/4T TO 16T, TFE/PLT/4T TO 16T, TFE/HBT/4T TO 16T, TFE/RIA/4T TO 16T,

TFE/RFT/4T TO 16T.